

BOARD OF COUNTY COMMISSIONERS

Kevin Beckner
Victor D. Crist
Ken Hagan
Al Higginbotham
Lesley "Les" Miller, Jr.
Sandra L. Murman
Mark Sharpe



Office of the County Administrator
Michael S. Merrill

CHIEF ADMINISTRATIVE OFFICER
Helene Marks

CHIEF FINANCIAL ADMINISTRATOR
Bonnie M. Wise

DEPUTY COUNTY ADMINISTRATORS
Lucia E. Garsys
Sharon D. Subadan

FIRE MARSHALS OFFICE

December 2013

Consumer Fireworks Retail Sales Facilities

Consumer Fireworks Retail Sales Facility (CFRS Facility)

A permanent or temporary building or structure, CFRS stand, *tent*, canopy or membrane structure that is used primarily for the retail display and sale of consumer fireworks to the public.

1. 1 water fire extinguisher & 1 2A-10BC fire extinguisher. Visible and accessible. *NFPA 1 - 65.11.3.6.3*
2. At least one sign that reads as follows, in letters at least 2 in. high on a contrasting background, shall be conspicuously posted at each entrance or within 10 ft of every aisle directly serving the CFRS area in a store: FIREWORKS- NO SMOKING - *65.11.3.11.2*
3. Temporary CFRS facilities shall not be located within 50ft of motor vehicle fuel-dispensing station dispensers - *65.11.3.12.2*
4. The minimum number of exits provided from the retail sales area shall be not less than three or as determined in accordance with Chapter 14 and NFPA 101, whichever number is greater - *65.11.3.14.1.1*
5. Exits shall be marked by an approved exit sign in accordance with section 14.14 and NFPA 101/ - *65.11.3.14.5.1*
6. Exit signs shall be required to be self-luminous or internally or externally illuminated - *65.11.3.14.5.2*
7. The means of egress, including the exit discharge, shall be illuminated whenever the facility is occupied in accordance with Section 14.13 and NFPA 101 - *65.11.3.14.6.1*
8. Emergency lighting shall be provided for CFRS facilities and stores and shall comply with Section 14.13 and NFPA 101 - *65.11.3.14.6.2*
9. Flame Breaks- read section - *65.11.3.15.3*
10. The area located within 30ft of a CFRS facility shall be kept free of accumulated dry grass, dry brush, and combustible debris - *65.11.4.6.1*
11. Parking- read section - *65.11.4.6.2*

Post Office Box 1110 • Tampa, Florida 33601

www.hillsboroughcounty.org

An Affirmative Action/Equal Opportunity Employer

Page #2 Consumer Fireworks Retail Sales Facilities

12. At least one sign that reads as follows, in letters at least 4 in. high on a Contrasting background, shall be conspicuously posted on the exterior of each side of the CFRS facility: NO FIREWORKS DISCHARGE WITHIN 300 FEET - *65.11.4.6.3*
13. Separations- read table - *65.11.4.7.2*
14. Exit openings from tents shall have a clear opening width of not less than 44 in. - *65.11.4.8.5*
15. Temporary wiring installed in a temporary structure, including tents and canopies, shall comply with Article 305 of NFPA 70 - *65.11.4.9.1.1*
16. Portable generators shall be located no less than 20ft from the CFRS Facility - *65.11.4.9.2.2*
17. Cooking equipment of any type shall not be permitted within 20 ft of tents, canopies, or membrane structures used for the storage or sale of consumer fireworks - *65.11.4.9.3.1*
18. Open flame cooking equipment of any type shall not be allowed within 50 ft of tents, canopies or membrane structures used for the storage or Sale of consumer fireworks - *65.11.4.9.3.1*
19. *There shall be a minimum of 20 ft between the tent and any structures..- 65.11.4.7.2*